

	Southern Adish Gas Condensate Refinery							 Southern Adish Gas Condensate Refinery								
	INSTRUMENT DATA SHEET FOR COOLING TOWER															
	Project	Phase	Unit	Disc	Type	Seq.No	Rev.									
SACR	306	CWS	IN	DHS	0052	03		12 of 13								
General Data	Class : 1															
	Tag No.		See List1													
	Equipment No.		See List1													
	Service		Cooling Tower													
	Quantity		3													
	Service Operation Temperature															
	Humidity		100%													
	Mounting		Surface Mounted													
Switch	Case Material		High resistance aluminium alloy													
	Type		Mechanical													
	Form		SPDT													
	Current & Voltage of contact rating		15A & 380Vac													
	Weather protection		IP65													
	Cable Entry		1xM20x1.5													
	Hazardous protection		Exd IIC T6													
	Vibration Range		0 ~ 5 (g)													
	Calibration Range		0 to 5 g with outer calibration screw													
	Set Point		To be carry out on site													
	Supply Voltage		N.A.													
	Cable Gland		N.A.													
	Connection	Connection Size		M20x1.5												
Mounting Bracket		Yes														
option	Manual Reset		Yes													
List1 <table border="1"> <tr> <td>Tag No.</td> <td>Equipment No.</td> </tr> <tr> <td>VS-522-001</td> <td>CT-001</td> </tr> <tr> <td>VS-522-002</td> <td>CT-002</td> </tr> <tr> <td>VS-522-003</td> <td>CT-003</td> </tr> </table>									Tag No.	Equipment No.	VS-522-001	CT-001	VS-522-002	CT-002	VS-522-003	CT-003
Tag No.	Equipment No.															
VS-522-001	CT-001															
VS-522-002	CT-002															
VS-522-003	CT-003															